

Message Text

LIMITED OFFICIAL USE

PAGE 01 KARACH 01700 061138Z

ACTION OC-06

INFO OCT-01 EA-10 NEA-10 ISO-00 SY-05 CCO-00 FBOE-00

A-01 OCL-00 /033 W

-----015262 061142Z /14

O R 061100Z APR 78

FM AMCONSUL KARACHI

TO SECSTATE WASHDC IMMEDIATE 3228

INFO AMCONSUL HONG KONG

AMEMBASSY ISLAMABAD

AMEMBASSY NEW DELHI

LIMITED OFFICIAL USE KARACHI 1700

ISLAMABAD FOR AO AND RSO; NEW DELHI FOR ATO;

HONG KONG FOR RSS

E.O. 11652: NA

TAGS: ASEC/AFAC/ABLD

SUBJECT: CCC RENOVATION

REF: STATE 82232

1. MR. BRYFOGLE COULD NOT BE DESIGNATED PROJECT OFFICER FOR THIS RENOVATION AS HE HAS BEEN ON R&R AND IS NOT EXPECTED TO RETURN TO POST UNTIL APPROXIMATELY APRIL 15 POST WILL PROCEED WITH CCC RENOVATION WORK AS BEST IT CAN UNDER PREVAILING CONDITIONS. PLEASE ADVISE ON THE FOLLOWING:

A. VENTILLATOR FAN AND MOTOR OVER ROOM NUMBER EIGHT HAVE APPARENTLY BEEN MISSING FOR YEARS. CAN DEPARTMENT IDENTIFY AND PROCURE TYPE AND MODEL ORIGINALLY INSTALLED OR AN INTERCHANGEABLE SUBSTITUTE? ADVISE.

LIMITED OFFICIAL USE

LIMITED OFFICIAL USE

PAGE 02 KARACH 01700 061138Z

B. INSTEAD OF FABRICATING AND INSTALLING ANEW AIR VENT IN THE NEW SOUTH PENTHOUSE WALL, POST SUGGESTS RETAINING COMPLETE STEEL WALL ASSEMBLY CONSISTING OF DOUBLE DOORS AND OVERHEAD LOUVERED VENT COMPLETE WITH TWENTY-FOUR INCH MOTORIZED FAN, AND TO SIMPLY MOVE IT OUTBOARD TO NEW WALL LOCATION. IF DEEMED NECESSARY, SECURITY GRILLE CAN BE ADDED. ADVISE.

C. IF QUARTER INCH PLATE OVER BEAM SUPPORTS, SHOWN ON DRAWING C5451.07-S-05(X) IS TO BE ON BOTH THE HILLER AND GENERATOR BASES, WE ASSUME THAT FOR GENERATOR BASE IT IS ONLY TO EXTEND OVER PORTION INSIDE PENTHOUSE. ADVISE.

D. DRAWING C541.07-S-03(X) SHOWS THE AREA BETWEEN W-6 AND W-7 TO BE REINFORCED. DETAIL (A) IMPLIES THAT THE REINFORCEMENT IS TO BE DONE WITH EIGHT INCHES OF CONCRETE. AS WE READ THE DRAWING, RAISING THE INTERIOR FLOOR BY EIGHT INCHES WOULD NOT SUPPORT THE GENERATOR AS THE BEARING SUPPORTS ARE TWELVE INCHES HIGH. ALSO, ADDITION WOULD NOT EXTEND OVER BOTH LOAD BEARING WALLS AND WOULD THUS ADD MORE THAN FOUR TONS TO THE ROOF LOADING. POST UNAWARE OF NEED FOR ANYTHING IN THIS AREA EXCEPT FOR REMOVING BUILT-UP ROOF AND INSULATION. ADVISE.

E. POST WOULD ALSO APPRECIATE DEPARTMENT'S RE-EVALUATION OF NEED FOR CLOSING ALL WINDOWS IN ROOMS TEN AND ELEVEN SINCE WINDOWS ARE HEAVILY BARRED AND ON FOURTH FLOOR OF BUILDING. ONE WINDOW WITH HINGE, LOCKABLE GRILLE IS PRESENTLY THE ONLY MEANS OF ESCAPE FROM VAULT/SAFEHAVEN AREA. IF ALL WINDOWS ARE SEALED THERE WILL BE NO MEANS OF EMERGENCY EXIT. LIMITED OFFICIAL USE

LIMITED OFFICIAL USE

PAGE 03 KARACH 01700 061138Z

AS MINIMUM, WINDOWS IN ROOM ELEVEN SHOULD BE ADAPTED FOR ESCAPE PURPOSES. ADVISE.

F. IF DEPARTMENT CONCURS, POST SUGGESTS FUNDING INCREASE OF DOLS 1000 FOR PROCUREMENT AND DELIVERY TO KARACHI OF TWO NEW 17000 BTU AIR CONDITIONERS FOR AC INSTALLATION NUMBER TWO AND NUMBER THREE ROOM TEN. ADVISE. MOORE

LIMITED OFFICIAL USE

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 jan 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 06 apr 1978
Decaption Date: 01 jan 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 20 Mar 2014
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1978KARACH01700
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Expiration:
Film Number: D780148-0879
Format: TEL
From: KARACHI
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1978/newtext/t19780487/aaaacvgh.tel
Line Count: 103
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: d2945cb5-c288-dd11-92da-001cc4696bcc
Office: ACTION OC
Original Classification: LIMITED OFFICIAL USE
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: LIMITED OFFICIAL USE
Previous Handling Restrictions: n/a
Reference: 78 STATE 82232
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 13 may 2005
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 3057185
Secure: OPEN
Status: NATIVE
Subject: CCC RENOVATION
TAGS: ASEC, AFAC, ABLD
To: STATE
Type: TE
vdkgvwkey: odb://SAS/SAS.dbo.SAS_Docs/d2945cb5-c288-dd11-92da-001cc4696bcc
Review Markings:
Sheryl P. Walter
Declassified/Released
US Department of State
EO Systematic Review
20 Mar 2014
Markings: Sheryl P. Walter Declassified/Released US Department of State EO Systematic Review 20 Mar 2014